

# Pulse v Event Logging



- Any Radcom logger can be programmed in Pulse or Event mode
- **Pulse** – Standard most adapted by users, averaging the number of pulse's out over a logged period to store the recorded value
- **Event** – Records the first pulse collected and calculates the time between it and the next pulse, main benefit for loggers on large meters with small flows, avoids “blocking” graphing effect (typically used when there is less than 1 pulse per logging period).

