



Ref: FAQ0238

Version: 1.0


Title - Radwin how to correct meter readings

Made By: AB 18/09/15


(Issue 2)

How to correct meter readings in Radwin software

From Radwin View – Click on the ‘Open Data File’ icon – top left area of screen
Find the logger you want to change and highlight it –



Right click on it and select location database and Edit location to see below -





Ref: FAQ0238

Version: 1.0

Title - Radwin how to correct meter readings

Made By: AB 18/09/15

(Issue 2)

Select the Meter Tab and the 'Readings' button - edit in the reading for a particular time and date, and 'save'

Radwin meter readings should now increment at the same rate as HWM Online – however note that HWM Online is taking a direct reading from the logger whereas Radwin is calculating the meter reading from the flow data it is receiving (HWM Online is likely to be more accurate)

Document History:

Edition	Date of Issue	Modification	Notes
1st	04/01/13	Release	
2nd	17/09/15	Format update	