



Ref: FAQ0254

Version: 1.0

Title – Radwin-mobile phone alarms

Made By: AB 21/09/15

(Issue 2)

## Interpreting Radcom logger SMS Text alarms received by a mobile phone

Example Alarm message received on a mobile phone

23:46 31 08-11-12 , 0000003 ,Ch 1 ,Pressure ,Low ,Balyhogue Chlor 0053.60 "5F303030303030301045360080B0C18028000"

It translates like this –

23:46 31 08-11-12	0000003	Ch 1	Pressure	Low	Balyhogue Chlor	0053.60	"5F303030303030301045360080B0C18028000"
Date and time of alarm	Radwin site ID (Zone & location )	Channel in alarm	Channel alarming	Type of alarm	Comment from Radwin logger config file	low press alarm at 53.6 metres	Data value in hex form (for Radwin database)

### Document History:

Edition	Date of Issue	Modification	Notes
1st	02/01/13	Release	
2nd	17/09/15	Format update	