

AQUAFLUSH INSTALLATION GUIDE

MAN-535-0003-A

A Crosbie

Document Control

Issue	Details	Author	Date
A	Initial release	AC	04/02/2014



AquaFlush Setup Guide


Version 1



Warning: This manual contains important safety and operating information. Please read, understand and follow the instructions in the manual.

Installing Legion dual unit

1. Connect flush system



2. Run SW-535-0001__Aquaflush Programmer
3. Select com port for 553-010 (fig.1)
4. Enter unit ID (fig.2)
5. Click on get configuration (fig.3) then hold magnet on test point of the unit for 3 to 5 seconds. Status window (fig.4) should read **configuration received**.
6. Update the following fields: Test Days, Valve Option, Valve Open Times and Working Hours. (fig.5)
7. Click configure unit (fig.6) then hold magnet on test point for 3 to 5 seconds. Status window should read **ACK Received – Unit Configured**.

8. Hold magnet on test point again for 3 to 5 seconds status window should read **Time received - Unit Clock Configured**.
9. Click start test (fig.7) then hold magnet on test point for 6 seconds unit should run flush test.
10. Status window should read Pass or Fail after test.

The screenshot shows the AquaVision software interface with several numbered annotations:

- 1:** Points to the "Communications Port" section, specifically the "Off" radio button.
- 2:** Points to the "Unit ID" input field.
- 3:** Points to the "Get Configuration" button.
- 4:** Points to the instruction "Enter unit ID then click Configure".
- 5:** Points to the "Test days" section, specifically the "Sunday" checkbox.
- 6:** Points to the "Configure unit" button.
- 7:** Points to the "Start Test" button.

The interface includes a clock showing 11:23:27, a "Valve Option" section with "Single" and "Dual" radio buttons, a "Valve Open Times (minutes)" section with "Cold" and "Hot" dropdowns, and a "Working hours" section with "Start" and "Finish" dropdowns. On the right, there is a table with columns "Unit ID", "Received Time", and "Temperature".

HWM-Water Ltd
Ty Coch House
Llantarnam Park Way
Cwmbran
NP44 3AW
United Kingdom
+44 (0)1633 489479
www.HWM-water.com

MAN-535-0003-A (Version 1)

